



**Wood Pole Condition Guide Objectives** 

Improve the accuracy and efficiency of wood pole condition assessment and increase consistency within the utility industry.












#### •Apendix·A → Visual·assessment·images¶

 $Failure \cdot Mode : \cdot Ground \cdot Line \cdot Decay \P$ 







Electricity Engineers' Association

5

### Guidelines for sounding assessments


Table 8: Comparative Sound characteristics for hammer tests.

Scenario	Frequency (pitch)	Decay time	'qualitative sound'	Hammer rebound
Solid	Higher	Longer	Crisp ring	firmer
Internal decay	Lower	Shorter	Dull or dead	softer
Hollow void	Lower	Longer	Hollow	softer





### Guidelines for probing/below ground assessments



Pole Size	d1 average (mm)	a1 (mm)	d3 (mm)	Defect grade
150 – 199mm	15	157	30	D1
200 – 249mm	20	196	50	D1
250 or greater	30	235	50	D1





7

### **Advanced Assessments**

- Usually proprietary, applying technology and data processing.
- The guide does not pick winners, but rather discusses selection criteria and how an advanced assessment should be incorporated into an overall program.





Defect Level	Criteria	Indicative intervention time	Indicative Inspection/maintenance requirement	Condition input to AHI
D5	Protective systems are fully functional.  No loss of capacity.  No loss of functionality.  No flaws.	25+	Normal Inspection	H5
D4	Protective systems showing signs of depletion.  No loss of capacity.  No loss of functionality.  Initial indicators of flaws that might in time develop in significance.	10-25	Increased Inspection	H4
D3	Protective systems functionally depleted. Initial stages of deterioration evident, minor loss of capacity. Developing flaws that could result in end of life. No loss of functionality.	5-10 years	Increased Inspection, consider opportunistic replacement with other works.	НЗ
D2	Significant deterioration and loss of capacity not exceeding design allowance for ultimate loads.  Non-critical loss of functionality. Presence of significant flaws not exceeding acceptable threshold	5 years	Schedule for planned intervention, increased inspection.	H2
D1	Loss of capacity exceeds design allowance for ultimate loads.  Loss of critical functionality. Flaws exceeding acceptable threshold.	1 year (as per regulation)	Planned Intervention, increased inspection, implement access restrictions.	H1
D0	Loss of capacity exceeds design allowance for normal loads.  Critical loss of functionality presenting an immediate safety hazard. Flaws exceeding hazard threshold.	3 months maximum.	Priority Intervention, implement access restrictions.	H1

## Proposed standardised meaning for tags

Table·11: Meaning·of·pole·tag·colours¶

Tag·Colourn	Meaning¤	Criterian
Red¤	Extreme·Caution·—·do· not·climb¤	A structure, including pole-top assembly's and setting that has been assessed to be at risk of failing under normal loads and must not be climbed.¤
Orange/Yellowia a	Caution·—·do·not·climbα	A-structure, including-pole-top-assembly's and- setting-that-has-been-assessed as incapable- of-meeting-design-loads and must-not-be- climbed.¤
Blue¤	Caution —·do·not·climb <sup>∞</sup>	A-structure-the-asset-owner-considers-as- unsuitable-for-climbing-for-any-reason-other- than-those-defined-by-Red-or-Orange/Yellow- tags¤



# **Project Schedule**

- Targeted draft to be completed by April 1.
- Currently 80% done
- Working through remaining issues to gain a consensus document.
- Issue consultation draft end May





11

### **Conductor Condition Assessment**

#### **Purpose of the Guide**

- 1. Provide industry guidance for the assessment of overhead conductor health for evaluating serviceability and forecasting end of life.
- 2. Provide a visual assessment framework for conductor types commonly used in New Zealand to creating commonality in grading (for both engineering and disclosure purposes) and for exploring future correlations between visual assessment, remnant strength and serviceability.
- 3. Provide a common data collection framework to assist with information sharing between interested NZ EDB's and a possible common database.
- 4. To provide guidance on the development of a network wide conductor condition model utilising the UK DNO Common Methodology as a modelling method.





# Project history

- Started in 2020
- Small team worked during lockdown remotely to develop concepts and outline.
- Project stalled due to work commitments late 2020.
- Was parked pending development of wood pole guide so that the conductor guide will be consistent.
- Ready to start again now.






13

## **Conductor Grading Scale**

Conductor Health Indicator	Definition
H1	Significant deterioration is present which compromises the Serviceability and safety. Approximate reduction in strength >20%
H2	Material deterioration is present which is expected to reduce the strength and serviceability. Approximate reduction in strength in the range of 11-20%
нз	Deterioration is present which marginally reduces strength or serviceability.  Approximate reduction in strength in the range of 6 – 10%
H4	Normal in-service deterioration affecting appearance. None to minor reduction in strength or serviceability of 0 - 5 %
Н5	As new condition, no observable deterioration or reduction in strength or serviceability.







15

## **Other Content**

- Discussion of other condition assessment tools
- Standard specification for laboratory tests
- · Guide to photographing conductors
- Common data collection template
- Guidance to constructing a CNAIM conductor model.



Electricity Engineers' Association



16

### **Other Content**

- Discussion of other condition assessment tools
- Guide to photographing conductors
- Standard specification for laboratory tests
- Common data collection template
- Guidance to constructing a CNAIM conductor model.





17

# **Next Steps**

- Ready to restart
- If you are interested in being a part of the development let us know.



