



Integrating Growing PV Installations on Queensland's Distribution Network




Part of Energy Queensland

Electrical Engineers Association NZ, January 2022



1

Our Network



Our 17 service areas


1 Far North	7 Capricornia	15 Brisbane North
2 Tropical Coast	8 Bundaberg Burnett	14 Brisbane Central
3 Herbert	9 Fraser Burnett	13 Brisbane South
4 Flinders	10 Darling Downs	16 Ipswich Lockyer
5 Pioneer	11 South West	17 Gold Coast
6 Central West	12 Sunshine Coast	

Our statistics


- 7,526** employees
- 2.3 million** connected customers
- 461** apprentices
- 746,000** retail customers
- 178,000km** overhead powerlines
- 1.7 million** power poles
- 29,000km** underground power cables
- 3** customer solutions centres
- 3** network control centres
- 33** stand alone power stations
- 37** large-scale solar renewables connected
- 690,000** small-scale solar energy systems connected

2

Ongoing uptake of solar PV



SOLAR PV AC CAPACITY ENERGEX AND ERGON ENERGY COMBINED



Legend:


- Premium (44c FIT)
- Regional/Retail FIT
- Other (>30kVA)
- Solar Farms (>5MW)

NB. Solar farms connected to Powerlink's transmission network are not included

3

Distributed Solar PV (DPV) causing reverse flows leading to network voltage and capacity constraints

110/33kV Bulk Supply - Spring Load Profile with Increasing DER



Legend:

- 2011
- 2012
- 2013
- 2014
- 2015
- 2016
- 2017
- 2018
- 2019
- 2020
- 2021


4

Distribution voltage management



5


MV Regulation



14 January 2022 Voltage management on distribution networks with high PV penetrations – Peter Kilby, Energy Queensland

6

240V (±6%) Regulation



14 January 2022 Voltage management on distribution networks with high PV penetrations – Peter Kilby, Energy Queensland

7


7

230V Standard in Qld

In October 2017 an amendment was made to the Queensland Electricity Regulation mandating a transition from the 240V to 230V standard by 26 October 2018.

Qld Supply Voltages		Existing (AS2926-1987)	Proposed (AS60038-2012)
Nominal	V_{n}/V_{ll}	240/415V	230/400V
% Range		+6%/-6%	+10%/-6%
Max/V99%	V_{99}/V_{ll}	254.4/440V	253/440V
Min/V1%	V_{1}/V_{ll}	225.6/390V	216/376V
Range	V_{99}/V_{1}	29/50V	37/64V
V50% (AS61000.3.100)	V_{50}/V_{ll}	-	225V-244V / 392V-424V

Comparison of Low Voltage Standards




8

230V Transition

- Phase 1 (Nov 2017 – Oct 2018):
 - From 225.6-254.4V to 216-253V LV range
 - MV (11kV & 22kV) reductions across state, primarily at zone substations of 1-2% to maximise impact (limited by OLTC buck taps/high transmission voltages)
- Phase 2 (Nov 2018 – June 2020):
 - Increased compliance with Preferred range 225-244V (AS61000.3.100)
 - More targeted reductions at remaining substations, MV regulators and also distribution transformers based on revised tap plans, monitoring and customer feedback
- Phase 3 (July 2020 onwards):
 - Ongoing response to issues identified by maximum and minimum demand forecasts, by monitoring and customer feedback

9

230V (+10/-6%) Regulation




14 January 2022 Distribution voltage management, high PV penetrations and the 230V transition – Peter Kilby

10

10

Reverse Flow & Voltage Regulation



14 January 2022 Distribution voltage management, high PV penetrations and the 230V transition – Peter Kilby


11

11


Voltage and capacity constraints on the LV network



12



13




14

Improved distribution voltage management

- Targeted distribution transformer tap reductions
 - Targeted at sites with high PV penetrations and modest peak demand voltage drop
- Widespread MV reductions to transition from the 240V standard to 230V
 - From 225.6-254.4V to 216-253V LV range
 - Increased voltage headroom for reverse flows
 - Median supply voltage compliance with Preferred range 225-244V (AS 61000.3.100)
- Application of line drop compensation to buck MV during reverse flow & minimum demand
 - Applied at zone substations and on MV feeder regulators
 - Reduces voltage spread at end of distribution feeders and accommodates additional feeder voltage rise
 - Constrained by buck tap range on some On Load Tap Changers (OLTCs)

15




16

Steady-state voltage distribution




17

Transformer Monitoring – Jan 2021




18

Low Voltage Monitoring – Jan 2021



19

Low Voltage Monitoring – Peak week Feb 2021



20

Smart Inverters and Grid Support Functions (GSF)

AS/NZS 4777.2:2020 Grid connection of energy systems via inverters, Part 2: Inverter requirements



21

Large Reactive Power Capability




Figure 2.1 — Minimum reactive power capability

22

Volt-var response, mitigating voltage rise from reverse flow




Figure 3.2 — Example curve for the volt-var control mode AS/NZS 4777.2:2020

23

Volt-watt response, limiting active power above 253V




Figure 3.1 — Example curve for the volt-watt response mode

AS/NZS 4777.2:2020


24

Changing reactive power demand




25

PV inverters with GSF are absorbing reactive power at minimum demand



26

Active Power Vs Reactive Power




27

Dynamic Operating Envelopes (DOE)




28




Dynamic operating envelopes

- A DOE specifies a varying operating range at the connection point for exports and/or imports.
- This can apply to a range of distributed energy resources (DER) including PV, BESS, EV etc.
- It can be used in conjunction with autonomous GSF to ensure network/system constraints are not breached by DER operation.
- While DOE are initially limited by existing visibility and systems, as capabilities scale and grid visibility increases, the DOE we send to active DER can be optimised
- IEEE 2030.5 Smart Energy Profile (SEP2) is the proposed protocol
 - CSIP-AUS – Australian version of the Common Smart Inverter Profile


29




30




31




32



33



34



35

From passive PV to active DER

- In just over a decade solar PV capacity in QLD has increased 1000 fold, primarily on the distribution network
- The 230V standard & improved distribution voltage regulation accommodates more voltage rise/PV
- Advanced autonomous inverter GSF mitigate impacts and maximise PV penetration
- DOE enables active DER management & DER service participation to maximise hosting capacity

36


References

- 1) Energy Queensland, "Energy Queensland Annual Report 2020-21." [Online]. Available: https://www.energen.com.au/_data/assets/pdf_file/0010/939484/Energy-Queensland-Ltd-Annual-Report-2020-21.pdf
- 2) Ergon Energy Network, "Distribution Annual Planning Report." [Online]. Available: <https://www.ergon.com.au/network/network-management/future-investment/distribution-annual-planning-report>
- 3) Energen, "Distribution Annual Planning Report." [Online]. Available: <https://www.energen.com.au/about-us/company-information/company-policies-and-reports/distribution-annual-planning-report>
- 4) Grid connection of energy systems via inverters, Part 2: Inverter requirements, AS/NZS 4777.2: 2020.
- 5) C.G. Kaloudas, L.F. Ochoa, B. Marshall, S. Maithiia and I. Fletcher, "Assessing the Future Trends of Reactive Power Demand of Distribution Networks", IEEE Trans on Power Syst., vol. 32, no. 6, 2017.
- 6) Ergon Energy Network & Energen, "Enabling Dynamic Customer Connections for Distributed Energy Resources," December 2021. [Online]. Available: <https://www.talkingenergy.com.au/dynamicconnections>

37




38




39




40




41




42



43



44



45

Summary on volt-var

- Reactive power mitigates voltage rise associated with active power generation from DER with much less impact on output than active power curtailment
- This is true even on LV networks with relatively low X/R ratios
- Volt-var response only requires significant reactive power (associated with modest active power curtailment at full output) near voltage limits unlike fixed power factor or reactive power modes.
- Imposing volt-var response sooner (closer to nominal), ensures more DER on a distribution network contribute and mitigate voltage rise, reducing number of customers exposed to higher voltages that require volt-watt response

46